



OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 441
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: (352) 343-9473
www.lakegovernment.com

ADDENDUM NO. 1

Date: February 25, 2015

Invitation to Bid (ITB) 15-0210

PROVIDE AND INSTALL A VEHICLE CANOPY AT FIRE STATION 90/104

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid response. Acknowledgement may be confirmed either by inclusion of a signed copy of this addendum with the initial bid response, or by completion and return of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the bid from being considered for award.

This addendum DOES NOT change the date for receipt of bids or proposals.

The purpose of this addendum is to provide confirming information, and answers to various vendor questions, resulting from the non-mandatory pre-bid conference held February 23, 2015. **The current due date remains in effect unless specifically changed via formal addenda.** A copy of the attendee list for the pre-bid conference has been posted to the County website for the above-cited Invitation to Bid.

The pre-bid conference commenced with the following matters being reviewed and confirmed:

1. Responses are due March 11, 2015 at 3:00 PM.
2. Award will be made to the lowest priced, responsive, and responsible bidder.
3. It was confirmed that the pre-bid conference was non-mandatory in nature.
4. It was confirmed that bonding is not required.
5. The completion intervals stated the ITB were confirmed.
6. ITB sections 1.13 regarding delivery and content of bid responses were reviewed.

7. ITB provision regarding alternate product was specifically noted
8. Vendors are to pay taxes on items they purchase for inclusion in the final project.
9. Operation of the County's reciprocal preference was confirmed.
10. Liquidated damages applied per Facilities terms and conditions attached to ITB.
11. That the primary site work effort would be completed by a third party vendor in conjunction with the road and paving construction effort shown on the site plan included with the ITB, but that the stem wall shown on the building drawings was to be installed by the building contractor.
12. The driveway under the canopy will be installed by a third-party vendor. Canopy vendor is responsible for canopy baseplate structure and utility infrastructure stubbed out 4 feet from the canopy structure.

The following questions were expressed during and after the meeting. County responses immediately follow each question:

Question 1: Is this one site that goes by two different #'s?

Answer 1: It is one site with two numbers, one canopy to be installed at one location.

Question 2: Are gutters and downspouts required?

Answer 2: No

Question 3: Is it okay to design the building as 2 bays as opposed to the 4 shown?

Answer 3: Yes, drawings can be considered conceptual but the structure does require PBR paneling on one wall as shown in the structure drawing.

Question 4: Will the top of slab elevation be the same as the base plate elevation?

Answer 4: Does not matter as long as clearance requirements are met.

Question 5: Are the ridge vents required?

Answer 5: No, ventilation is required, but various alternatives can be proposed.

Question 6: Do you want all of the structural members to be galvanized or just the secondary frames?

Answer 6: All members galvanized as specified in the ITB.

Question 7: Do you have an importance factor?

Answer 7: No

Question 8: Is a sprinkler system required?

Answer 8: Yes, meeting all NFPA requirements, with all components constructed of galvanized steel as currently specified in the ITB.

Question 9: Would insulated piping in the sprinkler system be acceptable in lieu of galvanized steel piping?

Answer 9: Yes

Question 10: Estimated value?

Answer 10: The formal estimated value for the effort under this ITB is \$134,851.

Acknowledgement of Addendum:

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _ _____